

FIRE PREVENTION

- Are flammable liquids, such as gasoline, kept in approved safety cans?
- Are materials or equipment stored in such a way that sharp objects will not interfere with the walkway?
- Are floor openings covered or otherwise guarded?
- Are standard guardrails provided wherever aisle or walkway surfaces are elevated more than 48" about any adjacent floor or the ground?
- Sprinkler heads or pipes are clear from any items hanging on them?
- Are the fire alarm sounders and strobe lights clear of obstructions?
- Are the fire pull stations in the area clear of obstructions?
- Are doors, passageways or stairways that are neither exits nor access to exits and which could be mistaken for exits, appropriately marked "NOT AN EXIT," "TO BASEMENT," "STOREROOM," etc.?

EXITS

- Are all exits kept free of all obstructions?
- Are exits properly marked?
- Are all fire exit doors closed?
- Are the directions to exits, when not immediately apparent, marked with visible signs?
- Can exit doors be opened from the direction of exit travel without the use of a key or any special knowledge or effort when building is occupied?
- Are storage areas uncluttered -- providing clear evacuation routes in the event of an emergency?
- Cabinets and lockers containing hazardous materials are equipped with positive latching or sliding doors?
- Is there at least 18" between the top shelf items and the ceiling? This space will allow ceiling sprinklers to function properly if a fire occurs.

| Yes | No | N/A | Comments |
|-----|----|-----|----------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| Yes | No | N/A | Comments |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

